



Plant: Midlothian Cement 245 Ward Rd. Midlothian, TX 76065

SPECIFICATIONS
 Masonry Cement
 Type N
 32 kg. Bag Weight
 A.S.T.M. C91-23

Bin Number					
Car Number					
Tons					
Date of Sampling		January-2026 Monthly Average			
		ASTM SPECIFICATION		TEST RESULTS	
PHYSICAL REQUIREMENTS					
Retained No. 325 Sieve, Maximum Percent		24		3	
Gillmore, Initial Set	Minimum (Minutes)	120 min	1000 max	275	
	Maximum (Minutes)			395	
Air Content, Volume	Minimum Percent	8		16	
	Maximum Percent	21			
		MPa	psi	MPa	psi
7 Day Minimum Compressive Strength, MPa (psi)		3.4	500	18.7	2707
28 Day Minimum Compressive Strength MPa (psi)		6.2	900	19.7	2852
December-2025					
Water Retention, Minimum Percent		70		87	

STATE OF TEXAS

ELLIS COUNTY

We certify that the above described cement, at the time of shipment meets the chemical and physical requirements of ASTM C - 91 specification.

2/18/2026

Todd Camp - Area QC Manager

Date